



**Dominion**

# DAM INSPECTION CHECKLIST POSSUM POINT POWER STATION POND ABC

INSPECTION DATE: APRIL 19, 2016

WEATHER: 63°F + PARTLY CLOUDY

INSPECTED BY: K. ACREE

Location/ Condition	(y/n)	Change (y/n)	Comments
Low Point, A dike*			
Flow	N	N	9:01 → SAND BAGS AND RIPRAP ARE IN-PLACE NO STANDING WATER AGAINST SAND BAGS OR FLOW
Erosion	N	N	SEVERAL RIPPED SAND BAGS
Low Point, B dike*			
Flow	N	N	9:05 → SAND BAGS ARE IN-PLACE NO STANDING WATER AGAINST SAND BAGS OR FLOW
Erosion	N	N	<del>NO SAND BAGS</del> SOME SAND BAGS ARE RIPPED
Outfall water surface El. (top of stoplogs to water)			9:14 → NO FLOW THROUGH WEIR, NO STANDING WATER AGAINST WEIR, AND WEIR APPEARS TO BE DRY

\* See figure below.

Additional Comments (Note any changes observed along the embankment crest or downstream slope observed from the crest.):

- LOW POINT, C DIKE ⇒ 9:11 → SAND BAGS ARE IN-PLACE, NO FLOW OR EROSION WAS OBSERVED, NO STANDING WATER AGAINST SAND BAGS, AND SEVERAL SAND BAGS ARE RIPPED.
- SOME STANDING WATER WITHIN LIMITS OF ALL THREE PONDS (PONDS A, B, & C)
- STANDING WATER AT TOP OF EMBANKMENT TO THE PONDS (PONDS A, B, & C); SEE FIGURE BELOW.

